


INSTALLATION INSTRUCTIONS

1. ENSURE THE APERTURE IS CLEAN AND FREE OF DEBRIS AND LOOSE CEMENT. REMOVE DUST FROM SURFACES REQUIRING INSTALLATION.
2. APPLY INTUMASTIC HP AROUND THE PIPE 10MM - 40MM ANNULAR, FULL DEPTH OF CONCRETE FLOOR (100MM MINIMUM).
3. REMOVE EXCESS MATERIAL WITH DAMP CLOTH.



Products: INTUMASTIC HP
Approvals: AS 1530.4/AS 4072.1
BK:
Ref: RIR 26371
ID: H12/H13
Scenario: Penetration seal to combustible pipes.
Construction: Concrete floor 100mm min.
Annular: 10mm - 40mm annular.
Fire Integrity: 120 minutes.
Insulation: 120 minutes.
Services: Up to 43mm dia. PEX/PEX AL gas pipes.

Web based drawings are for example only, fire performance of any system is dependant on, but not limited to size of opening, substrate, if penetrations are passing through, type, size and number. Please refer to Ryanfire technical department for detailed and specific fire performance information.



Client

Job Title

Drawing Title

Intumastic HP to Combustible Pipe Penetration - Concrete Floor

Scale **NTS** Date **July 2019**

Sheet Size **A3** Drawn By

Drawing Number **V22.6** Rev **2.0**

Please note: Ryanfire Products Ltd owns and has copyright in these drawings. They are to be used only for the purpose for which they were intended and supplied and are not to be sold, transferred or made available for use by a third party.

Any misuse of these drawings will result in legal proceedings.

All errors and omissions excepted - the Information contained within this drawing is believed to be correct on the date of publication, and is based upon tested and certified solutions. The policy of **RyanFire Products Ltd** is one of constant improvement. Installers must therefore ensure that they are following the latest published drawings, test evidence and instructions. Whilst **RyanFire Products Ltd** will endeavour to keep its publications up to date, the accuracy of the information contained within this drawing may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of the **manufactured** products. Terms and conditions of sale apply.

RYANFIRE Technical Support: info@ryanfire.co.nz - Tel 09 443 0362